

Nicor Ex. 13

Document Name: Rates

AC0567 Completion Detail CAD Ticket 03-20021024-0240  
Report Code 54 COMPL Subcode 1 Worked 10/24/02 by 11551  
1711 W VICTORIA DR MT PROSPECT POSTED  
Times: Prev finish En-route At job Completed  
Reported 11:53 12:08 12:18 12:48 Vehicle 2514  
Actual 12:08 12:18 12:48

NO CHARGE Read 0392 AC check: OK  
Odorant check: OK CO Device Alarmed: DIDNT USE Two-man:  
Gas indic used: GAS TRAC Testhand:  
Tags: Cent Ht Room Htr Water Htr Range Dryer Piping Other Cust Adv

Comments:

FOUND REG PASSING BADLY, REPLACED SAME, SEE 09 TICKET.

Next-Prev (N/P) N Xmit

FILED  
03-0367  
Nien  
EXHIBIT No. 13  
3/31/04  
Ec

Date: 8/14/ 3 Time: 02:30:27 PM